

FIREPRO® ABLATIVE COATED BATT 50MM AND 60MM

<http://dop.rockwool.com>

1. Unique identification code of the product-type	UK-WER-0222-01_english
2. Intended use of the construction product as foreseen by the manufacturer, in accordance with the applicable harmonised technical specification	Fire Stopping and Sealing Penetration Seal. The field of application has to comply with the content of ETA15/0337
3. Name, registered trade name or registered trade mark and contact address of the manufacturer, as required pursuant to Article 11(5) of regulation (EU) No 305/2011	ROCKWOOL® Limited Pencoed, Bridgend, CF35 6NY
4. Applicable System or Systems of Assessment and Verification of Constancy of Performance (AVCP)	SYSTEM 1
5. European Assessment Document (EAD) number and date of issue	ETAG 026-01 (General) ETAG 026-02 (Firestopping and FireSealing Products) Issued in June 2013(Part1) October2011(Part 2) N/A Issued in N/A
6. European Technical Assessment (ETA) number and date of issue	ETA 15/0337 Issued in 27th October 2015
7. Technical Assessment Body (TAB) name	Warrington Certification Limited
8. Notified Body identification number	1121
9. Declared Performances	Please refer to the table below (NPD – No Performance Determined)

ETAG Clause No.	ETA Clause No.	Product characteristics	Assessment of Characteristics
		MECHANICAL RESISTANCE AND STABILITY	Not relevant
		SAFETY IN CASE OF FIRE	
2.4.1	3.1	Reaction to Fire	Class F according to EN13501-1
2.4.2	3.2	Resistance to Fire	Resistance to fire performance and field of application in accordance with EN13501-2 See ETA 15/0337 Clause 3.2 Annex C
		HYGIENE, HEALTH AND ENVIRONMENT	
2.4.3	3.3	Air permeability	Tested in accordance with EN 1026 See ETA 15/0337 Clause 3.3
2.4.4	3.4	Water permeability	N/A
2.4.5	3.5	Release of dangerous substances	See ETA 15/0337 Clause 3.5
		SAFETY IN USE	
2.4.6	3.6	Mechanical resistance and stability	NPD
2.4.7	3.7	Resistance to impact / movement	N/A
2.4.8	3.8	Adhesion	NPD
		PROTECTION AGAINST NOISE	
2.4.9	3.9	Airborne sound insulation	See TDS FirePro® Ablative Coated Batt - Rw (C;Ctr) = 32dB & 21dB
2.4.10	N/A	Impact sound insulation	NPD
		ENERGY ECONOMY AND HEAT RETENTION	
2.4.11	N/A	Thermal properties	NPD
2.4.12	3.10	Water vapour permeability	NPD
		GENERAL ASPECTS RELATED TO FITNESS FOR USE	
2.4.13	3.11	Durability and serviceability	Z1 (0/+40°C) intended for use at internal conditions with high humidity (85%) in

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Bob PERRY
Production Director



